



## The potential of power-to-gas

A technology review and economical potential assessment

18 December 2015





## Introduction

Historical background and technology status

Methodology for case studies analysis

Results of the case studies analysis




## Identity

**25 people independent consulting company**

**Core business: Energy transition for industry**

**Ethical model: Pro Bono Energy Access in Developing Countries**



### Technology:

benchmark, roadmaps

### Strategy:

markets, R&D positioning

### Projects:

PFS, Performance, Impact

**Our offer**

## Our clients

## Our fields of operation

### Energy players



### Energy consumers



### Technology & Engineering



### Startups



### Public Sector



- Energy storage
- Mobility (H2, biofuels, CNG, GNL)
- Biogas, biomass
- Renewable power & Smart grids
- CO<sub>2</sub> capture and utilization



## What is the potential for power-to-gas as a solution to valorise power for energy markets ?

- ▶ Massive development of renewable electricity production from intermittent sources is underway in Europe.
- ▶ With the merit order effects this produces periods of low spot prices of electricity.
- ▶ This represents an opportunity for the development of flexible electrointensive processes.
- ▶ Power-to-gas is one of these processes that can be considered as a solution to convert power into a fuel gas for energy markets.





## The study assesses the potential of power-to-gas and alternative power-to-X processes targeting energy markets

- ▶ Power-to-X is the conversion of electricity in an energy carrier X
- ▶ Power-to-gas: production of gaseous fuels (hydrogen or synthetic natural gas)
- ▶ Power-to-liquids: production of liquid fuels (methanol, synthetic diesel...)
- ▶ Power-to-heat: production of heat (steam, hot water)
- ▶ Power-to-power is not considered (electricity storage)



# Power-to-X as defined in the study can imply various routes, products and target different market





# Agenda

Introduction


**Historical background and technology status**

Methodology for case studies analysis

Results of the case studies analysis




# Historical development of power to gas; from concept to industrial demonstration









# Most of R&D projects (pilot & demonstration) have been launched since 2012, specifically for methanation





# Europe is leading global R&D activity on PtG, specifically in Germany where 17 industrial pilot and demonstration projects have been launched



■ Power-to-Hydrogen  
■ Power-to-Methane

**And in the rest of the world ?**

- R&D activity on PtG is limited outside of Europe
- Japan is active in R&D for the development of hydrogen markets but not on the production side
- USA has recently announced its first PtG project



## Water electrolysis: alkaline is the reference technology but could be challenged by PEM in the future, solid oxide electrolysis is still at laboratory stage of development

### ▶ Alkaline electrolyzers

- Reference technology used in industry
- Efficiency between 66% and 74% depending on the pressure of H<sub>2</sub> delivered
- Installed CAPEX ranges from 1,000 to 2,000 €/kWe depending on the capacity
- Slight margin of improvement on energy efficiency
- Cost reduction can be achieved but will remain limited (technology improvement and market volume effects)

### ▶ PEM electrolyzers

- Technology under demonstration
- Efficiency is comparable to alkaline technology
- Installed CAPEX for large capacities could reach 1,000 €/kWe at commercial stage, and decrease down to 400 €/kWe in 2050

### ▶ SOEC operates at high temperature to increase the energy efficiency but requires further development to confirm its performances and costs



## Catalytic methanation is the most mature and investigated route for H<sub>2</sub> and CO<sub>2</sub> conversion into CH<sub>4</sub> but still requires technology development

### ► Catalytic methanation

- Technology at demonstration status for power-to-gas applications
- The chemical reaction produces large amounts of heat
- Methanation is well known and controlled in the industry for large scale units and continuous operation
- Power-to-gas applications imply smaller scale units and intermittent operation and require new types of reactors (i.e. isothermal instead of adiabatic)
- R&D challenges are the control of the temperature inside the reactor and its operational flexibility
- CAPEX estimates for catalytic methanation vary widely in the literature and from project developers (400 to 1,500 €/kW<sub>HHV-SNG</sub>).

### ► Biological methanation

- Offers an alternative with convenient temperatures levels (20-70°C)
- Faces scale-up challenges due to inherent limitations (mass transfer inside the reactor and kinetics of the reaction)



# Agenda

Introduction


Historical background and technology

**Methodology for case studies analysis**

Results of the case studies analysis



# The analysis is based on 6 case studies focusing on potential mass market applications for energy






**We compare the levelized cost of the final product with the market price of alternative products on the target market, for 3 time horizons (2015, 2030 and 2050)**

- ▶ LCOX is the levelized cost of the product X, it represents the breakeven selling price of the product
  
- ▶ LCOX is calculated from
  - Capital expenditures (CAPEX) of the plant
  - Operational expenditures (OPEX) of the plant over the lifespan
  - Production of the plant over the lifespan
  - Weighted Average Cost of Capital (WACC)
  
- ▶ CAPEX, OPEX and production are calculated from a process bloc analysis
  
- ▶ WACC is considered as 8%



## CAPEX and OPEX are estimated per block for equipment, installation and project costs

- ▶ CAPEX & OPEX are calculated **per block** in the plant (electrolyzer, compression, methanation reactor...)
- ▶ CAPEX of a block have been assessed as a breakdown of project costs, factory gate cost of equipment and additional costs:
  - With project costs = 30% of Equipments CAPEX
  - Installed CAPEX are assessed from interviews, literature, ENEA's projects
- ▶ OPEX = Electricity & CO<sub>2</sub> consumption + O&M costs
- ▶ O&M costs are assumed to be fixed and based on the installed CAPEX (%CAPEX/year)



### Note

When not available, additional costs are assumed as:

- 50% of factory gate cost for methanation & methanol synthesis
- 15% of factory gate cost for compression






# The price of electricity is the most volatile and critical OPEX for power-to-X plants

- ▶ Power-to-X plants should be operated preferably when the price of electricity is low


Spot NordPool prices of electricity in Denmark (DK1 zone) during the first week of January 2014





# Electricity spot prices can be sorted hourly in a year from the lowest to the highest to give a price duration curve


## Electricity spot price duration curve for selected European zones in 2014





The average wholesale price of electricity for a power-to-X plant operating at the cheapest hours depends on the load factor and is calculated with the minimum average electricity spot price curve

- ▶ Operation on the cheapest hours requires the plant to be ideally flexible






# For 2030 and 2050 time horizons, prospective scenarios of electricity price available in the literature were used

## ► Sources used from the literature

- Thesis published in 2011 by Marco Nicolosi (EWI – University of Köln)
- Presentation performed in 2013 by Alfred Voss (IER – University of Stuttgart)
- Report published in 2014 by DNV GL in cooperation with the Imperial College and NERA Economic Consulting


**Prospective price duration curves derived from models and published in the literature.**





# Finally, one minimum average electricity spot price curve was selected for each time horizon

### Minimum average electricity spot prices selected





## The final consumer price of electricity also comprises grid fees and electricity taxes

- ▶ The consumer price for electricity is composed of:
  - The wholesale price (curves shown previously)
  - Grid fees
  - Electricity taxes, for renewable electricity feed-in tariffs notably
  
- ▶ Grid fees were assumed to be fully variable although they are generally composed of a fixed share. The value used in the model is 10€/MWh.
  
- ▶ 4 different assumptions on electricity taxes were used for LCOX calculation
  - No electricity taxes
  - 20€/MWh
  - 40€/MWh
  - 60€/MWh

### Note

Grid fees and electricity taxes values do not vary with timeframe (2015; 2030; 2050) in the model.



# Market values of competitor energy carriers

- ▶ Market values of competitor energy carriers are defined with low/high values
- ▶ For fossil fuels
  - The low value is the current market value without CO2 tax
  - The high value is the forecast market value 2030 (IEA WEO 2012) with a CO2 tax of 100€/tCO2
- ▶ For renewable fuels
  - The low value is the current (2015) lowest production cost or wholesale price
  - The high value is the current (2015) highest production cost or wholesale price

Market values of competitor energy carriers

		Low value	High value
<b>Mobility</b>			
Gasoline without taxes	€/100km	2,7	4,2
Gasoline with taxes	€/100km	6,6	9,1
Ethanol	€/100km	3,8	4,6
BioCNG	€/100km	5,6	12,6
<b>Gas grid injection</b>			
Natural gas wholesale	€/MWhHHV	22,0	47,8
Biomethane production cost	€/MWhHHV	62,1	103,4
<b>Industrial heat</b>			
Heat from natural gas	€/MWhth	32,7	62,3



# Agenda

Introduction

Historical background and technology

Methodology for case studies analysis


**Results of the case studies analysis**





# Total CAPEX of a plant varies significantly with scale effect and assumptions used on equipment cost decrease by 2030 and 2050


Total specific CAPEX of plants for the 3 time horizons








# To compete with biomethane, power-to-gas with grid injection requires drastic CAPEX reduction, very low electricity prices and relatively high load factor

## Levelized cost of fuels for grid injection from PtG plants at optimal load factors






# To reach low LCOX a power-to-gas plant with grid injection must run at a relatively high load factor (i.e. from 2,500 to 6,000 hours/year)





# Hydrogen and methanol produced from power already compete with bioCNG but are not likely to compete with fossil fuels without incentives



## LCOX of mobility fuels from PtG or PtL plants at optimal load factor



Scenario  
Load factor (h/year)  
Elec price (€/MWh<sub>el</sub>)




# To reach low LCOX a power-to-gas plant for mobility applications must run at a high load factor (i.e. more than 6,000 hours/year)






# The competitiveness of power-to-heat for industry with electrode boilers is highly depending on the spread between natural gas and electricity prices

## LCOX of heat from electrode boiler at optimal load factor





# Power-to-heat for industry with electrode boilers is suited for operation at reduced load factors (i.e. 1,000 to 2,000 hours/year)





# Green mobility is the most promising market for power-to-gas and should be the first target for large scale deployment of power-to-gas

- ▶ To reach competitiveness power-to-gas plants require:
  - To operate at a high load factor
  - To position on high product value markets
  
- ▶ Finally, power-to-gas plant should be resilient to the price level of electricity which means that other power-to-X routes (ex: power-to-heat) potentially competing for the “low cost electricity” resource are not a real threat
  
- ▶ To compete with biomethane, power-to-gas for grid injection requires dramatic CAPEX decrease and electricity available at very low cost which are not likely.
  
- ▶ H<sub>2</sub> production from power for the green mobility market already compete with bioCNG and could be incentivised to compete with fossil fuels in the long term
  - Financial incentives on product taxes are mandatory to compete with fossil fuels
  - The cost structure is relatively resilient to electricity price level
  - In the long term, CAPEX reduction of plants will allow for reduced financial incentives
  
- ▶ But other solutions for green mobility comes in competition






## A complementary analysis is worth to better assess the potential of power-to-hydrogen in comparison with the various available options for green mobility

- ▶ The present study is not oriented on mobility specifically and thus does not fully compare power-to-hydrogen with all other mobility options such as BioCNG, bioLNG, e-MeOH, biofuels 2G, electricity...
- ▶ A detailed comparison of these options, at country level and on multiple parameters is recommended to confirm the potential of power-to-hydrogen for this market:
  - Economics, CO<sub>2</sub> emissions and air pollution, service provided (ex: autonomy), technology readiness, geographical coverage and infrastructure required, ramp-up scenario...
- ▶ The potential of power-to-X processes for non energy markets has not been considered in this study but could play a role in technology development (ex: H<sub>2</sub> for industrial use).



# Enea Consulting, your energy project partner



- ▶ Energy storage integration in infrastructure and processes
- ▶ Energy Efficiency
- ▶ AMO, Project management

- ▶ Stakeholder Management
- ▶ Social Acceptance
- ▶ Global Performance

- ▶ Marketing, competition
- ▶ Business model optimization
- ▶ Project financing
- ▶ Investor advisory





**ENEA Consulting**  
**89 rue Réaumur, 75002 Paris**

**Tel : +33 (0)1 82 83 83 83**  
**[contact@enea-consulting.com](mailto:contact@enea-consulting.com)**  
**[www.enea-consulting.com](http://www.enea-consulting.com)**

**Jacques de Bucy**

Project Manager

Tel Fixe +33 (0)1 82 83 83 95

Mobile +33 (0)6 63 51 67 00

**[jacques.debucy@enea-consulting.com](mailto:jacques.debucy@enea-consulting.com)**



## Input parameters used in the model

Sensitivity analysis



# Input parameters used in the model (1/5)

## Legend

Hard parameter

Calculated from another parameter

General assumptions	Unit	Fixed	2015	2030	2050
Project costs	% of Total CAPEX of proces blocs	30,0%			
WACC	-	8,0%			
Load factor	h/year	6 000			
Electricity cost	€/MWh	20			
CO2 cost @ 10 bar	€/ton	50			
CO2 cost @ 100 bar	€/ton	100			
CO2 density	ton/Nm <sup>3</sup> -CO <sub>2</sub>	0,0018			
HHV volumic H <sub>2</sub>	MWh/Nm <sup>3</sup> -H <sub>2</sub>	0,0035			
HHV massic H <sub>2</sub>	MWh/kg-H <sub>2</sub>	0,0394			
HHV volumic SNG	MWh/Nm <sup>3</sup> -SNG	0,0113			
HHV massic SNG	kWh/kg-SNG	0,0145			
HHV massic MeOH	kWh/kg-MeOH	0,0056			

Power grid connection	Unit	Fixed	2015	2030	2050
Lifetime power grid connection	years	40			
Transformer capacity out - 1MW	MWe	1,0			
Transformer capacity out - 10MW	MWe	10,0			
Transformer losses	%	2,5%			
Length HV line	km	1,0			
Total CAPEX HV circuit breaker	€	125 000			
Specific CAPEX HV line	€/km	100 000			
Total CAPEX transformer	€	30 000			
Fixed OPEX power grid connection	%CAPEX/year	0,00			



## Input parameters used in the model (2/5)

### Legend

Hard parameter

Calculated from another parameter

<b>Alkaline electrolysis 10 bar</b>	<b>Unit</b>	<b>Fixed</b>	<b>2015</b>	<b>2030</b>	<b>2050</b>
Lifetime electrolyzer	<i>years</i>	25			
Electrolyzer capacity in - 1MW	<i>MWe</i>	1,0			
Electrolyzer capacity in - 10MW	<i>MWe</i>	10,0			
Electrolyzer efficiency	<i>kWhHHV-H2/kWhe</i>		66%	69%	69%
Electrolyzer capacity out - 1MW	<i>MWHHV-H2</i>	0,7			
Electrolyzer capacity out - 10MW	<i>MWHHV-H2</i>	6,6			
Specific CAPEX electrolyzer - 1MW	<i>€/MWe in</i>		1 500 000	1 000 000	800 000
Specific CAPEX electrolyzer - 10MW	<i>€/MWe in</i>		1 000 000	800 000	500 000
Fixed O&M electrolyzer - 1MW	<i>% CAPEX/year</i>	4,5%			
Fixed O&M electrolyzer - 10MW	<i>% CAPEX/year</i>	1,5%			
<b>Methanation</b>	<b>Unit</b>	<b>Fixed</b>	<b>2015</b>	<b>2030</b>	<b>2050</b>
Lifetime methanation reactor	<i>years</i>	20			
Methanation capacity out - 10MW	<i>MWHHV-SNG</i>	5,24			
Methanation efficiency	<i>MWhHHV-SNG out/MWhHHV-H2 in</i>	79,4%			
Specific cost methanation reactor - 10MW	<i>€/MWHHV-SNG out</i>		1 500 000	1 000 000	700 000
Additional cost methanation reactor	<i>% cost methanation reactor</i>	50%			
Fixed O&M methanation - 10MW	<i>% cost methanation reactor/year</i>	7,5%			
Methanation H2 consumption	<i>Nm3H2/Nm3SNG</i>	4,0			
Methanation CO2 consumption	<i>Nm3CO2/NmSNG</i>	1,0			



# Input parameters used in the model (3/5)

## Legend

Hard parameter

Calculated from another parameter

Compression H2	Unit	Fixed	2015	2030	2050
Lifetime compressor H2	<i>years</i>	15			
Compressor H2 capacity out - 1MW	<i>MW<sub>HHV</sub>-H2</i>	0,66			
Compressor H2 capacity out - 10MW	<i>MW<sub>HHV</sub>-H2</i>	6,60			
Cost compressor H2 - 1MW	€	200 000		180 000	160 000
Cost compressor H2 - 10MW	€	1 261 915			
Additional cost compressor H2	<i>% cost compressor</i>	15,0%			
Fixed O&M compressor H2 10-60bar	<i>% CAPEX/year</i>	6,0%			
Power consumption compressor H2 10-60bar	<i>MW<sub>he</sub>/MW<sub>HHV</sub>-H2</i>	-0,93			

Compression SNG	Unit	Fixed	2015	2030	2050
Lifetime compressor SNG	<i>years</i>	15			
Compressor SNG capacity out - 10MW	<i>MW<sub>HHV</sub>-SNG</i>	5			
Cost compressor SNG - 10MW	€	630 957			
Additional cost compressor SNG	<i>% cost compressor</i>	15,0%			
Fixed O&M compressor SNG 10-60bar	<i>% CAPEX/year</i>	6,0%			
Power consumption compressor SNG 10-60bar	<i>MW<sub>he</sub>/MW<sub>HHV</sub>-SNG</i>	0,02			



# Input parameters used in the model (4/5)

## Legend

Hard parameter

Calculated from another parameter

Pipeline H2 & SNG	Unit	Fixed	2015	2030	2050
Lifetime pipeline	<i>years</i>	35			
Pipeline capacity out - 1MW	<i>MW<sub>H2</sub></i>	0,66			
Pipeline capacity out - 10MW	<i>MW<sub>H2</sub></i>	6,60			
Pipeline length	<i>km</i>	1,00			
Fixed CAPEX pipeline H2 @10 bar	€	50 000			
Variable CAPEX pipeline H2 @10 bar	€/km	130 000			
Fixed CAPEX pipeline H2 @60 bar	€	200 000			
Variable CAPEX pipeline H2 @60 bar	€/km	300 000			
Fixed O&M pipeline	<i>% CAPEX/year</i>	-98%			
Injection station H2 & SNG	Unit	Fixed	2015	2030	2050
Lifetime injection station	<i>years</i>	15			
Injection station capacity out - 1MW	<i>MW<sub>H2</sub></i>	0,66			
Injection station capacity out - 10MW	<i>MW<sub>H2</sub></i>	6,60			
Total CAPEX distribution injection station - 1MW	€		600 000	480 000	360 000
Total CAPEX distribution injection station - 10MW	€		700 000	560 000	420 000
Total CAPEX transport injection station - 1MW	€		700 000	560 000	420 000
Total CAPEX transport injection station - 10MW	€		900 000	720 000	540 000
Fixed O&M injection station	<i>%CAPEX/year</i>	8,0%			





# Input parameters used in the model (5/5)

## Legend

Hard parameter

Calculated from another parameter

Refueling station H2	Unit	Fixed	2015	2030	2050
Lifetime H2 refueling station	years	30			
H2 refueling station capacity out - 1MW	MW <sub>HHV-H2</sub>	0,66			
Total CAPEX H2 refueling station - 1MW	€		3 000 000	1 800 000	1 620 000
Fixed O&M H2 refueling station - 1MW	%CAPEX/year	-92,5%			
Power consumption H2 refueling station	MW <sub>he</sub> /MW <sub>HHV-H2</sub>	-0,82			
Methanol synthesis	Unit	Fixed	2015	2030	2050
Lifetime methanol reactor	years	20			
Methanol reactor capacity out - 10MW	MW <sub>HHV-MeOH</sub>	4,99			
Methanol reactor H2 consumption	kgH <sub>2</sub> /kgMeOH	0,19			
Methanol reactor CO <sub>2</sub> consumption	kgCO <sub>2</sub> /kgMeOH	1,38			
Methanol synthesis efficiency	MW <sub>HHV-MeOH out</sub> /MW <sub>HHV-H2 in</sub>	0,76			
Specific CAPEX methanol reactor - 10MW	€/MW <sub>HHV-MeOH out</sub>		1 500 000	1 000 000	700 000
Additional cost methanol reactor	% cost methanol reactor	50%			
Fixed O&M methanol reactor - 10MW	%CAPEX/year	7,5%			
Electrode boiler	Unit	Fixed	2015	2030	2050
Lifetime electrode boiler - 10MW	years	40			
Electrode boiler capacity out - 10MW	MW <sub>th</sub>	10			
Electrode boiler efficiency	MW <sub>th</sub> /MW <sub>he</sub>	-1%			
Specific total CAPEX electrode boiler - 10MW	€/MW <sub>th out</sub>	89 999			
Fixed O&M electrode boiler - 10MW	%CAPEX/year	-98,8%			



Input parameters used in the model

**Sensitivity analysis**



## Conditions used for sensitivity analysis


- ▶ Common nominal parameters
  - Load factor : 6000 hour/year
  - Electricity price: 20 €/MWh
  - WACC: 8%
  
- ▶ Type of sensitivity analysis
  - LCOX structure: variation of +/- 10% on each parameter
  - Project and technologies: ranges on each parameter with uncertainties or potential improvements/underestimates




# Hydrogen injection at small scale (1 MWe)

- ▶ LCOX structure: CAPEX and electricity price
- ▶ Project & technologies: HV line & pipeline length, electrolyzer efficiency

### H2 injection 1 MWe Sensitivity analysis (+/- 10%)



### H2 injection 1 MWe Sensitivity analysis (range)







# Hydrogen injection at medium scale (1 MWe)

- ▶ LCOX structure: CAPEX and electricity price
- ▶ Project & technologies: Electricity price, electrolyzer efficiency, WACC

### H2 injection 10 MWe Sensitivity analysis (+/- 10%)



### H2 injection 10 MWe Sensitivity analysis (range)







# SNG injection (10 MWe)

- ▶ LCOX structure: CAPEX, electricity price and O&M methanation
- ▶ Project & technologies: electricity price, CAPEX and O&M methanation

### SNG injection 10 MWe Sensitivity analysis (+/- 10%)



### SNG injection 10 MWe Sensitivity analysis (range)







# H2 mobility (1 MWe)

- ▶ LCOX structure: CAPEX, O&M refueling station
- ▶ Project & technologies: CAPEX, electrolyzer efficiency, electricity price, O&M refueling station

### H2 mobility 1 MWe Sensitivity analysis (+/- 10%)



### H2 mobility 1 MWe Sensitivity analysis (range)







# Methanol mobility (10 MWe)

- ▶ LCOX structure: CAPEX, electricity price, O&M methanol synthesis
- ▶ Project & technologies: electricity price, CAPEX, O&M methanol synthesis, electrolyzer efficiency

### Methanol mobility 10 MWe Sensitivity analysis (+/- 10%)



### Methanol mobility 10 MWe Sensitivity analysis (range)









# Heat (10 MWe)

- ▶ LCOX structure: electricity price
- ▶ Project & technologies: electricity price

### Heat 10 MWe Sensitivity analysis (+/- 10%)



### Heat 10 MWe Sensitivity analysis (range)





## Variations on costs of technologies under development can significantly modify the LCOX (high uncertainty)

- ▶ CAPEX intensive blocks and O&M based on the CAPEX
- ▶ Wide range of value due to the lack of commercial maturity and feedback on the actual cost of these blocks

Type of parameter	Technology/block	Range (Low/Nominal/High)	Variation on LCOX
CAPEX	Injection station (distribution)	500/600/700 k€ for H2 injection (1 MWe)	-4% to +4%
CAPEX	H2 refueling station	2/3/4 M€ for 1MWe	-19% to +19%
CAPEX	Methanation reactor (without integration costs)	1200/1500/1700 €/kWout	-8% to +5%
CAPEX	Methanol synthesis (without integration costs)	1200/1500/1700 €/kWout	-7% to +5%
O&M	H2 refueling station	6%/8%/10% of CAPEX (with integration costs)	-8 to +8%
O&M	Methanation reactor	6%/8%/10% of CAPEX (with integration costs)	-5% to +5%
O&M	Methanol synthesis	6%/8%/10% of CAPEX (with integration costs)	-5% to +5%



## Variations on input consumption and price impact all case studies concerned but are controlled (low uncertainty)

- ▶ Electricity price and load factor are critical parameters that are the focus of our modelling with electricity price duration curves
- ▶ Electrolyzer efficiency
  - Current value (66% with auxiliaries) is well known from commercial operation
  - A slight improvement is assumed by 2030 (69%) due to auxiliaries mutualization
- ▶ CO2 price
  - The impact on the LCOX is limited
  - The purchase of CO2 can be discussed for methanation (free CO2 from biogas upgrading facility)

Type of parameter	Technology/block	Range (Low/Nominal/High)	Variation on LCOX
Energy efficiency	Electrolyzer	61%/66%/71%	-7% to +8% for H2 cases -4% to +4% for SNG & MeOH cases
CO2 price	Methanation	20/50/80 €/t <sub>CO2</sub>	-3% to +3%
CO2 price	Methanol synthesis	80/100/120 €/t <sub>CO2</sub>	-3% to +3%



## Long distances to power grid and gas grid can rapidly increase costs

- ▶ These parameters are sensitive for small scale capacities (1 MWe) and depend on the project
- ▶ A plant located at 10 km from the power grid or the gas grid and with a small production capacity (1 MWe) will be highly impacted by the CAPEX of HV line or pipeline.
- ▶ With a nominal value set at 1 km for both HV line and gas pipeline the potential for cost reduction is low.

Type of parameter	Technology/block	Range (Low/Nominal/High)	Variation on LCOX
Length	HV line	0/1/10 km	-2% to +17% for H2 1 MWe -1% to +10% for H2 mobility
Length	Gas pipeline	0/1/5 km	-3% to +12% for H2 1 MWe -1% to +5% for H2 10 MWe